


en

Schneider

Push-button plus with room temperature control unit


Operating instructions



System M



System M



Necessary accessories

- You have to complete the 2-gang push-button plus with a design frame system M

Push-button, 2-gang plus with room

Art. no. MTN6212-03../MTN6212-04...

Push-button, 4-gang plus with room

Art. no. MTN6214-03../MTN6214-04...

temperature control unit

temperature control unit

- You have to complete the 2-gang push-button plus with a design frame system M without central bridge piece (Art. no MTN4788... MTN4858... MTN4868... MTN4878.., MTN5158.., MTN4888).

For your safety

DANGER

Risk of fatal injury from electrical current. The unit may only be installed and connected by skilled electicians. Observe the regulations valid in the country of use, as well as the valid KNX quidelines.

Getting to know the push-button

The push-button plus with room temperature control unit (reffered to below as the push-button) gives you four (push-button 2-gang) or eight (push-button 4gang) operating surfaces. The keys can be set individually to perform various functions. Furthermore a room temperature control unit is integrated, which allows you to control temperature in various different ways.

Functions of the push-button:

- Switching, toggling, dimming, blind control
- Szenenfunktion
- Communication and disable functions - Time control with synchronisation, reading external
- temperature, fan control

Functions of the room temperature control unit:


- Heating/cooling with 1 controller output - Heating/cooling with seperated controller outputs
- Heating/cooling with 2 controller outputs

The push-button can directly be connected to the KNX and is parameterised by the electrical installer via the KNX-Tool-Software (ETS).

Scope of delivery (A)

- (A) Push-button
- B Cover
- © Foil strip
- D Safty screw
- E Sticker (only push-button 4-gang)

Connections, displays and operating elements



- A Display
- B LED
- © IR receiver
- Staus LED

Getting to know the keypad


The push-buttons opposite each other can be configured as either individual push-buttons or a push-button pair. The push-buttons are programmed with various functions depending on the pre-setting.

For 4-gang push-button only:


The 4-gang push-button is equipped with an IR receiver, with which you can control the push-button with any IR remote control. Pressing push-buttons 1-8 on the remote control activates the function of the corresponding pushbutton. Push-buttons 9 and 10 of the remote control have a direct effect on display push-buttons 9 and 10.

Mounting side

In order for the integrated room temperature control unit to work in the best way, you should keep in mind the following when selecting the right installation side:










Mounting the push-button

Push-button 2-gang and 4-gang






Only push-button 4-gang




Operating the push-button

① Set the push-button to programming state




2 Load the physical address and application from the ETS into the push-button: The red programming LED goes out.



Note for the electrician

Make sure that you note the settings you have made in the ETS which are important for the user in the configuration table (see "Pre-settings table"), because not all parameters that can be set are shown in the display of the push-button.


Anti-theft protection



Dismantling the push-button



 $\angle !$ The device could become damaged. Before removing the push-button, check whether it is secured with protection against theft. Always remove the protection against theft before removing the push-button.




You can also create and print corresponding foil strip templates with any layout program. Size specifications for foils (in mm): Push-button Height Width Thickness

2-gang	24,9	23	max. 0,15
4-gang	96,2	23	max. 0,15
Consult th	ne operating	instruction	s of your printer to find

out which type of foil strips you can print.

Only use the coloured foil strips enclosed as the i base, since this ensures that the push-button LEDs under the labelling field can shine through. Two versions of coloured foil strips are provided: i one with a recess in the middle for the IR receiver, and one without a recess. If you want to control the push-button via an IR remote control, you have to use the coloured foil strip with recess. Always only use one of the two coloured foil strips.

Closing the labelling field



Pre-settings

When installing the push-button, the electrician defines various settings that are necessary so you can use the push-button correctly. Most of the explanations provided on the following pages depend on these settings. The electrician enters the settings in question in a table for you (see table "pre-settings").

value in the table

Preface room temperature control unit/ display

With the integrated room temperature control unit, you can control the temperature in various different ways. You can read and set important information on the dis-

- play: Setpoint temperature
- Operating mode (comfort, standby, night, etc.)
- Working day/holiday
- · Display mode (setpoint temperature, actual temperature, date etc.)
 - · Background lighting
 - · Setting the time/switching time


Getting to know the display

•			
1	2	3	

You will see the following symbols on the display:

Â	Comfort mode or we perature is adjusted temperature 1.
∩)	The flashing symbol tension is active. Standby mode or ho ture is adjusted to th perature ≣. Night operation. The justed to the set nigh Time control is activ
\mathfrak{G}	Constant display: Th nised.
	Flashing display: Th chronised; the displa rate.
D	Alarm, symbol flashi ton: Additional acou ble 1
1234	Weekday display

- Ŷ ing" is activated. Fan. ん
- <u>}}}}</u> quires power.
 - quires power.
 - For heating or cooling: "1": Setpoint temperature has not yet been reached. The controller is heating or cooling. heating/cooling is set able: Manual or automatic
- °C Temperature display in degrees Celsius
- °F
- Temperature display in degrees Fahrenheit 88:88 Time display or value display



If you come across this symbol 🛓 when reading, it means that you can look up the corresponding



orking day. The room tem-I to the set comfort setpoint

means that the comfort ex-

oliday. The room temperane set standby setpoint tem-

e room temperature is adht setpoint temperature 🔳

he time has been synchro-

ne time has not been svnayed time may not be accu-

ning. For 4-gang push-butustic warning sound possi-

In combination with 1: Fan speed

Menu command "Setting the background light-

Heating control mode is active or controller re-

Cooling control mode is active or controller re-

Display under "Heating" or "Cooling" symbol.


"2": Level 2 is activated (display only if two-step

- For heating and cooling: Two modes are avail-


Getting to know the control menu

There is a control menu for selecting the individual functions of the room temperature controller

A rocker is integrated in the cover of the display. It has three contacts: left, centre and right. With these pushbuttons, you can access the control menu, scroll backwards and forwards and change individual values.



Overview of the menu structure



Push-button action Center -Long push-button action*

Function triggered Select menu Save Return to standard display

Center -Short push-button action** Select next menu com-

Left/Right -

mand

Short push-button action** Change value

*Long push-button action = approx. 5 s


**Short push-button action = approx. 1 s

If you don't press any push-button within a period of about one minute, the room temperature control unit automatically returns to the standard display. The values that were set before the control menu was opened are restored; any changes that you may have made are not saved. Exception: The temperature is saved directly.

Setting the room temperature control unit/display view


Standard display

Here you see an example of the standard display:




- Comfort" operating mode
- Actual temperature 20°
- Heating 🚆 is active in order to reach the comfort setpoint temperature
- 😢 is constantly displayed: The time has been synchronised with the time switch (e.g. year time switch REG-K). Clock symbol flashes: The time has not (yet) been synchronised.
- Weekday display 3 = Wednesday
- Note that the display of the weekday depends on Note that the display of the wooldary is the pre-settings. The electrician has set [], a specific weekday to 1. In some countries the first day of the week is not Monday, but Sunday, for example. The other numbers have different meanings accordingly (e.g., 2 = Monday, 3 = Tuesday etc.).

Setting the setpoint temperature





The electrician has specified three setpoint temperatures \blacksquare (for both heating and cooling):


- for comfort mode
- · for standby mode
- for night operation



The electrician specified 📃 , within which limits this value can be changed (for example, within a minimum of 16 °C up to a maximum of 26 °C). You cannot set any value below or above these limit values. If the electrician made the appropriate setting I , the 4-gang push-button emits a warning sound as soon as you attempt to exceed these limit values.











- b 0 = comfort mode Select this operating mode if you are staying in the room. The heating is set to the comfort setpoint temperature (e.g. 21 °C III).
- b 1 = standby mode Select this operating mode when you are not in the room over a longer period of time. The heating is set to the standby setpoint temperature (e.g. 18 °C III).
- b 2 = night operation) The heating is set to the night setpoint temperature (e.g. 15 °C 重).
- b 3 = comfort extension (flashes) Select this operating mode if you want to suppress night operation temporarily. The heating is set to the comfort setpoint temperature (e.g. 21 °C III).


The electrician may have set 1, the times at i which the operating mode switches automatically from night operation to comfort mode and vice versa



Setting the working day/holiday









Setting the display mode

With the display mode, you can select which values you want to see in the display.







- d 0 = actual temperature (without decimal point)
- d 1 = setpoint temperature (to 0.5 degree accuracy)
- d 2 = temperature from external temperature sensor
- d 3 = date
- d 4 = time
- d 5 = fan speed
- d 6 = date and time in alternation
- d 7 = date, time and fan speed in alternation
- d 8 = actual and setpoint temperature in alternation • d 9 = actual/setpoint temperature and time in alternation
- d 10 = actual/setpoint temperature and fan speed in alternation
- d 11 = temperature from external temperature sensor and actual temperature
- d 12 = temperature from external temperature sensor. actual temperature and time in alternation
- d 13 = actual/setpoint temperature, date and time in alternation
- d 14 = actual/setpoint temperature, fan speed and time in alternation
- d 15 = emperature from external temperature sensor, actual temperature, fan speed and time in alternation



Setting the background lighting

(1)









Setting the internal clock time and switching times


- If the time is updated by an external time switch, the updated time is displayed here. If you change this time manually, it will be overwritten again by the time switch during the next update.
- You can only use the control menu to adjust the | i | switching times which have been pre-programmed via the ETS. Switching times which are not defined in the ETS are shown when they are called up in the display with "--:--" and cannot be set using the push-buttons on the display.



(1)



- t 0 = time (either transmitted from the external time switch or from the internal clock)
- t 1.1 bis t 1.4 = time channel 1, switching time 1-4
- t 2.1 bis t 2.4 = time channel 2, switching time 1-4
- ③ Press central push-button and hold : he hour display for the selected time/switching time starts to
- ④ Press the left or right push-button on the display: Set the hours as desired
- (5) Press the central push-button briefly : The minute digits now flash.
- 6 Press the left or right push-button on the display: Set the minutes as desired.
- (7) Press the central push-button briefly: The set time (t...) appears again.
- 8 Press the central push-button briefly again: Save the desired new setting



•	Synchronise the time via an external time switch
	Synchronise the time via an external time switch to guarantee precision over a long period of time

Selecting the setpoint temperature or operating mode directly

The electrician specified I , whether you can access and adjust the setpoint temperature or the operating mode directly using the right/left push-button, or whether none of these functions is activated

(1) 1 x push-button left/right - short push-button action.

The menu command "Set setpoint temperature" or "Set operating mode" is displayed with the last set value Change the value by pressing the left or right push-button on the display. The value is saved directly; you don't have to save it separately. After approx. 5 s, the room temperature control unit returns automatically to the standard display.

Other display views

APL. Application not loaded

F 2 Heating setpoint tempe temperature

- E 3 ETS application is not compatible E 4
- range
- E 5 FRAM error F 6 Error in temperature sensor
 - E 7 STACK error
 - E 8 RAM error F9 Buffer error

Presettings table

-				
Push-button a	assignm	ent		
Push-button 1				
Push-button 2				
Push-button 3				
Push-button 4				
Push-button 5				
Push-button 6				
Push-button 7				
Push-button 8				
Time control	channel	1		
Switching	1	2	3	4
time				
Time _	:	:	:	:
Function: _				
Time control		•		
Time control	cnannei	2		
Switching	1	2	3	4
time				
Time	:	:	:	:
Function:				



witching	1	
ne		
me	:	
unction:		

Switching time	1
Time Function:	:

Alarm functions

Alarm sounds if actua
the frost protection te
Alarm sounds if the s
exceeded
Others:


Heating se	tpoints in °C/°F
Comfort:	
Standby:	
Night:	

mi Heating setpoints in °C/°E Adjustment limit in °C/°E

r lealing selp	Aujustitietti li	
Comfort:	 min:	max:
Standby:	 min:	max:
Night:	 min:	max:
Frost		
protection:	 min:	max:
Heat		
protection:	 min:	max:

Setpoint adjustment valid until: Operation mode change / Permanent Week starts (1): on Fri / Sat / Sun / Mon

Direct selection: Setpoint temperature / Operation mode / None



or faulty	
rature = cooling setpoint	

Upper control value range = lower control value

al temperature is less than emperature or etpoint adjustment limit is

Adjustment limit in °C/°F min: max: max.

in:	max:

Technical data

Power supply:	via KNX
Connection:	Bus connecting terminal
Display elements	J
Push-button	
2-/4-gang:	1x Display
	1x operational LED
Push-button 2-gang:	4x Status LED
Push-button 4-gang:	8x Status LED
	Piezo buzzer
Operating elements	
Push-button	
2-/4-gang:	3 push-buttons to navigate menu
Push-button 2-gang:	4 push-buttons
Push-button 4-gang:	8 push-buttons
	IR receiver
	(angle of reception: 60°)
Measuring range:	0 to 40 °C
Measuring accuracy:	± 1 K, depending on installa- tion site; Offset can be config- ured
Controller type:	2-step
	Continuous PI controller
	Switching PI controller (PWI)
Controller mode:	Heating with 1 controller output
	Cooling with 1 controller out- put
	Heating with 2 controller out- puts
	Cooling with 2 controller out- puts
	Heating and cooling with
	separate controller outputs
	2-step heating with 2 controller outputs
	2-step cooling with 2 controller outputs
	2-step heating and 2-step
	cooling with 4 control outputs
Type of protection:	IP 20

Schneider Electric Industries SAS

If you have technical questions, please contact the Customer Care Center in your country.

www.schneider-electric.com

This product must be installed, connected and used in compliance with prevailing standards and/or installation regulations. As standards, specifications and designs develop from time to time, always ask for confirmation of the information given in this publication.